



INSTANT FOUNDATIONS
 PO BOX 198 OSBORNE PARK, WA 6917
 TEL: (08) 9371 7711 FAX: (08) 9371 7722 MOB: 0408 071 581

STANDARD UNDERPINNING DETAIL FOR
 DOMESTIC HOUSING – SWL 75kN
 INSTALLATION TORQUE 8000Nm

PROJECT

CONSULTING ENGINEER

Drawing No.	UNDER75A
Certified:	
Date:	DEC '99
Scale:	1:20

DESIGN NOTES

- STRUCTURAL ENGINEER TO CONFIRM THAT EXISTING FOOTING /SLAB CONFIGURATION HAS THE CAPACITY TO SPAN BETWEEN THE SPECIFIED PILE CENTERS.
- APPLIED SWL OF 75kN PER PILE (MAXIMUM)
- MAXIMUM PILE DEPTH OF 4.0m.
- SOIL CONDITIONS ASSUMED TO BE MEDIUM DENSE SANDS WITH A 'n' VALUE > 10 OR CLAYS WITH A 'Cu' VALUE OF > 150.
- DESIGN LIFE IS 75 YEARS MINIMUM IN ACCORDANCE WITH AS2159.
- ALL STEELWORK TO COMPLY WITH AS4100.
- NO SECOND HAND STEEL TUBE TO BE USED.
- ALL CONCRETE WORK TO COMPLY WITH AS3600.
- INSTALLATION IS TO BE CONDUCTED BY AN APPROVED ACCREDITED INSTANT FOUNDATIONS INSTALLER HOLDING A CURRENT INSTALLING CERTIFICATE.